

STRUCTURAL SOUNDNESS CERTIFICATE

STATEMENT ACCOMPANYING FORM - A

- 1) Door number of the building : Nil
- 2) Location : **Maharishi Vidya Mandir School,**
(Street number, Ward number, S.F. No. 49/2B2, 49/2A,
Name of place, i.e. Corporation / Gopinathampatti X Road,
Municipality / Panchayat Union / Pulithiyur Village,
Township / Contonment) Kokkarappatti Panchayat,
Pappireddipatti Taluk,
Dharmapuri District.
- 3) Year of construction : 2018
- 4) Approximate cost of construction : Rs. 5,36,00,000/-
as per current rates
- 5) Purpose for which the building is : School, purpose
being used or proposed to be used
- 6) Purpose for which the building : School purpose
has hitherto been used
- 7) Details of construction of the building
(Particulars of the foundations soil,
Specification of various parts under)
- | | |
|-----------------------------------|--|
| a) Foundation | : RCC column & footing |
| b) Basement | : RCC column & plinth beam |
| c) Super structure | : Brick walls & Solid block wall |
| d) Floor and roof are to be given | : <u>Floor</u> <u>Roof</u> <u>Area</u> |
| | : Ground floor RCC roof 18031.00 sqft |
| | : First floor RCC roof 17809.12 sqft |
| | : Second floor RCC roof 17809.12 sqft |
- 8) Period for which licence is required : **01.06.2021 to 31.05.2024.**



- 9) No. of persons to be accommodated : **1800 Students only.**
(One thousand eight hundred students only)

Date : 23.06.2021

- Encl :-** 1. Declaration
2. Dharmapuri Collector Panel order
3. Blue print

Proceedings of Dharmapuri Dist.
Collector R.Dis. 62897 / 2000.

Signature of the Panel Engineer

Er. P.N.RAMESH BAABHU,
B.E., M.Tech., M.Sc.(R&V), MIE, FIV, FIGV, C.Eng(I), MIITA, MICI,
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-I/443-99)
Approved Valuer for Immovable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO
TLR ASSOCIATES
Mobile: 94434 42002. Email : tlrassociates@yahoo.com

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or portion of building originally is changed or altered subsequently.

This is further to certify that no thatched buildings / inflammable roof buildings are used within this premises for the purpose noted in the statement. Any thatched building constructed / used after issue of this certificate, I would be held responsible for fire accident / mishap that may occur later and I am aware of that it is a punishable crime.

It is also understood that the conditions of all existing, adjacent / other floors / or other buildings of any types within this premises which were not opted / covered for the purpose which the licence was granted would be brought under the risk of my own.

We are well aware of that the underground amenities like water sumps, septic tanks, borewells and open wells should be kept always in closed rigid conditions for all time safety measures to students / publics.

Date : 23.06.2021

Signature of the owner of the building

FORM - B

(Form of Certificate of Structural Soundness under sub-section(4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation :

- | | | |
|---|---|-----------------------|
| i) Depth below ground level | : | 2.13 m |
| ii) Nature of soil met with at foundation level | : | Soft Gravel |
| iii) Pressure at foundation | : | 100 kN/m ² |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m ² |

2) Super structure :

- | | | |
|--|---|--|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - 0.20 N/mm ²
Concrete - 5.00 N/mm ² |
| ii) Nature of Masonry & Concrete and its safe permissible stress | : | Brick work - 0.35 N/mm ²
Concrete - 9.00 N/mm ² |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from
01.06.2021 to 31.05.2024.

Date : 23.06.2021

Proceedings of Dharmapuri Dist.
Collector R.Dis. 62891 / 2000. _

23/6/21
Signature of the Panel Engineer

Er. P.N.RAMESH BAABHU,
B.E., M.Tech., M.Sc.(ReV), MIE, FIV, FIGV, C. Eng(I), MIITA, MICI,
Chartered Engineer (M-119996-6/99)
Govt. Approved Valuer (E 1410)

STATEMENT TO ACCOMPANY**THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1)	Location of the building (Door No, street name and name of the place)	Maharishi Vidya Mandir School, S.F. No. 49/2B2, 49/2A, Gopinathampatti X Road, Pulithiyur Village, Kokkarappatti Panchayat, Pappireddipatti Taluk, Dharmapuri District.
2)	Age of the building	3 years
3)	The Value of the building as per current rate	Rs. 5,36,00,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC framed structure
6)	Purpose for which the building is certified for use	School purpose
7)	The period for which the building will be structurally sound	01.06.2021 to 31.05.2024.
8)	No. of persons to be accommodated	1800 Students only. (One thousand eight hundred students only)
9)	Remarks	Nil

Date : 23.06.2021

Signature of the Panel Engineer

Proceedings of Dharmapuri Dist.,
Collector R.Dis. 62891 / 2000.

Er. P.N.RAMESH BAABHU,
B.E,M.Tech,M.Sc(ReV),MIE,FIV,FIGV,C.Eng(I),MHTA,MICI,
Chartered Engineer (M-119996-6/99)

FORM - C

(Form of Certificate of Structural Soundness under sub-section (4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamilnadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation :

- | | | |
|---|---|-----------------------|
| i) Depth below ground level | : | 2.13 m |
| ii) Nature of soil met with at foundation level | : | Soft Gravel |
| iii) Pressure at foundation | : | 100 kN/m ² |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m ² |

2) Super structure :

- | | | | |
|--|---|--------------|------------------------|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - | 0.20 N/mm ² |
| | : | Concrete - | 5.00 N/mm ² |
| ii) Nature of Masonry & Concrete and its safe permissible stress | : | Brick work - | 0.35 N/mm ² |
| | : | Concrete - | 9.00 N/mm ² |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from

01.06.2021 to 31.05.2024.

Date : 23.06.2021

Signature of the Panel Engineer

Er. P.N.RAMESH BAABHU,
B.E.,M.Tech.,M.Sc(Rev),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI,
Chartered Engineer

STATEMENT TO ACCOMPANY**THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1)	Location of the building (Door No, street name and name of the place)	Maharishi Vidya Mandir School, S.F. No. 49/2B2, 49/2A, Gopinathampatti X Road, Pulithiyur Village, Kokkarappatti Panchayat, Pappireddipatti Taluk, Dharmapuri District.
2)	Age of the building	3 years
3)	The Value of the building as per current rate	Rs. 5,36,00,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC framed structure
6)	Purpose for which the building is certified for use	School purpose
7)	The period for which the building will be structurally sound	01.06.2021 to 31.05.2024.
8)	No. of persons to be accommodated	1800 Students only. (One thousand eight hundred students only)
9)	Remarks	Nil

Date : 23.06.2021

Signature of the Panel Engineer


DECLARATION

I, **Er. P.N. Ramesh Baabhu** son of Mr. P.M. Natarajan residing at D.No.1A, TAMS Colony II cross, Old Railwayline road, Dharmapuri - 636701, Dharmapuri District do hereby declare that I possess the qualification and experience specified in the Table Rule 11 of the Tamil Nadu Public Buildings (Licensing) Rules 1966, for issuing the Certificate of Structural Soundness of the building covered by the certificate.

I am an **APPROVED & REGISTERED ENGINEER** with the **Collector of the Dharmapuri District** under Tamil Nadu Public Buildings (Licensing) Act 1965 & Rules 1966 to issue the Structural Soundness Certificate to public buildings.


Signature of the Panel Engineer

- | | | | |
|----|---------------------------|---|---|
| 1) | Name in Block letters | : | P.N. RAMESH BAABHU |
| 2) | Engineering Qualification | : | BE, M.Tech, M.Sc(Val), MIE, FIV, CEng(I), MIITA, MICI, MASMI |
| 3) | Experience | : | <ul style="list-style-type: none"> * 32 years as a Chartered Civil Engineer. * Regd. Valuer for Income Tax Department. * Approved Engineer by Board of Engineers, Tamil Nadu Govt, from 1999 onwards. * Govt. Approved Valuer. * Regd. Engineer Class-1A category. * Panel Engineer with the Collector of Dharmapuri District (R.Dis 62891/2000) |

Note :

- 1) This certificate contains 7 pages and covers only the buildings mentioned therein not any other buildings in the premises.
- 2) Maintenance of the above buildings should be made periodically.
- 3) If the certificate is tampered illegally or made any corrections/alterations without permission, knowledge, signature of the undersigned, this certificate will automatically get cancelled.
- 4) This certificate never covers and out-of-scope for any natural disasters like earthquake, cyclone, fire and any other impacts which affects the stability of the buildings brought under the purview of this certificate.
- 5) The underground water sumps, septic tanks, bore wells and open wells should be kept always in good condition and repaired immediately if any damage occurs.

தருமபுரி மாவட்ட ஐ.கீ. தலைவர் அவர்களின் நடவடிக்கைகள்

முன்னிலை: திரு. கா. பாலசுந்தரன் இ.ச.ப.

ந.மு.எ.கீ.உ. (ஆ1) 62 891/2000

நாள் 27.1.2001

பொருள்: திரையரங்குகள் - தருமபுரி மாவட்டம் பொறியாளர் பட்டியல் தருமபுரி மாவட்டம் - பொறியாளர் திரு. பி.எஸ். ரமேஷ் பாபு என்பவர் பெயர் பட்டியல் சேர்த்து இணைப்பில்.

பாரிவை: சென்னை பொதுப்பணித் துறை முதலமை பொறியாளர் (ஜெனரல்) கழக என்.எஐடி.டி 1/ஜெ.உ/52898/2000 நாள் 11.1.2001.

.....

ஆணை:

1. தருமபுரி மாவட்டம் மற்றும் நகரில் வகித்து வரும் பொறியாளர் திரு. பி.எஸ். ரமேஷ் பாபு என்பவர் 1965ம் வருட தமிழ் நாடு பொதுக் கட்டடங்களின் கீழ் தருமபுரி மாவட்டம் பொறியாளர்களின் பட்டியல் சேர்க்கை கோரி விண்ணப்பித்தார்.

2. மேற்படி பொறியாளரின் விண்ணப்பம் தேவையான பந்த குறைகளுடன் சென்னை பொதுப்பணித் துறை தலைமை பொறியாளர் அவர்களுக்கு அனுப்பப்பட்டது.

3. மேற்படி முன்மொழிவுகளைப் பொறியாளர் சூலீராஸ் பரிசீலனை செய்யப்பட்டு மேற்படி பொறியாளர் திரு. பி.எஸ். ரமேஷ் பாபு என்பவரை கிளாஸ் 1 பிளவில் தயாரி பொறியாளர்களுக்கான பட்டியல் சேர்க்கலாடி என பாரிவையில் குறிப்பிடப்பட்ட கடிதத்தில் தெரிவிக்கப் பட்டுள்ளது.

4. பாரிவையில் குறிப்பிடப்பட்ட கடிதத்தில் குறிப்பிடாத காரணிகள் திரு. பி.எஸ். ரமேஷ் பாபு என்பவரை தருமபுரி மாவட்டத்தில் 1965ம் வருட பொது கட்டடங்களின் உரிமையாளர்களின் கீழ் தருமபுரி மாவட்டம் பொறியாளர்கள் பட்டியல் கிளாஸ் 1 பிளவில் சேர்த்து இடமில்லாத இணைப்பில் குறிப்பிடப்பட்டுள்ளது.

/உகிமை நகல்/

ஒ.கா.பாலசுந்தரன்,
மாவட்ட ஐ.கீ. தலைவர்

தலைமை பொதுப்பணி (குற்றியல்) 6

பெயர்

திரு. பி.எஸ். ரமேஷ் பாபு, பி.இ.
டி.எல்.ஜி. அசோக்யேட்டி

முதல்தளம் டி.கே.கே. காண்புகள்

ஒப்புதல் பெற்ற பதிவுசெவ்வல்.

பெயர் ரோடு

தருமபுரி 636701

நகல்: செயற்பொறியாளர், பொதுப்பணித் துறை கட்டடக் கோட்டம், தருமபுரி-5

கண்காண்புப் பொறியாளர், பொதுப்பணித் துறை கட்டட (கட்டுமானம்) 1

931
27.1.2001

FORM-D

Form of the License under Section (12) of the Tamil Nadu Public Building License Act 1965.+

License No.11/2021

Fees Rs.1,000/-
(Rupees one Thousand only)

License is hereby granted to the Correspondent, MAHARISHI VIDYA MANDIR SCHOOL (CBSC), Gopinathampatti X Road, Puluthiur Village, Kokkarapatti Post, Pappireddipatti Taluk, Dharmapuri District for the purpose of running a School in the buildings specified in the statement below, subject to the conciliations and for the period mentioned here under.

The period of validity of the License shall be for the period from 01.06.2021 to 31.05.2024.

Place : Pappireddipatti
Date : 06.07.2021


TAHSILDAR
PAPPIREDDIPATTI


STATEMENT TO ACCOMPANY THE LICENSE.

Location of the Building Door No. S.F.No. and Name of the Place	Purpose of which the building is licensed to the used as a public building	No. of persons to be accommodated
S.F.No.49/2B2, 49/2A Maharishi Vidya Mandir School (CBSC), Gopinathampatti X Road, Puluthiur Village, Kokkarapatti Post, Pappireddipatti Taluk, Dharmapuri District	Education Purpose	1300 Students 160 Staffs

Place : Pappireddipatti
Date : 06.07.2021




TAHSILDAR
PAPPIREDDIPATTI